

# Flanged External Cage Float Actuated Liquid Level Switches

#### DESCRIPTION

External cage type level switches are completely selfcontained units designed for side mounting to a tank or vessel with threaded or flanged pipe connections. In hundreds of industrial applications throughout the petroleum refining, petrochemical production and power generation markets, these switches have thoroughly demonstrated their worth for years.

#### FEATURES

- Carbon steel float chamber.
- Easy inspection of float chamber through removable head.
- Stainless steel float and trim.
- Service pressures up to 900 psig (62 bar).
- Process temperatures up to +1000° F (+538° C).
- Specific gravity ratings as low as 0.40.
- Available switch styles including dry contact, hermetically sealed and pneumatic.
- Operating level differentials field-adjustable.
- Single or multiple switch mechanisms available.
- Available switch enclosures include:

NEMA 1 carbon steel for pneumatics

TYPE 4X/7/9 Class I, Div. 1 Groups C & D aluminum

TYPE 4X/7/9, Class I, Div. 1, Group B, aluminum

- 1", 1½", or 2" tank connections available in either NPT, socket weld, flanged side/side or flanged side/bottom construction.
- Optional high temperature insulation available. See bulletin 41-106.



### APPLICATIONS


- Accumulators
- Flash tanks
- Receivers
- Knockout drums
- Flare pots
- Storage tanks
- Scrubbers
- Separators

#### OPTIONS

- Interface calibration
- Extreme temperature modifications
- · Customized installation dimensions
- Special exterior surface preparation and finish
- Special tank connections
- Special actuation levels

#### TECHNOLOGY

A permanent magnet ① is attached to a pivoted switch actuator and adjustment screw ②. As the float ③ rises following the liquid level, it raises the attraction sleeve ④ into the field of the magnet, which then snaps against the non-magnetic enclosing tube ⑤, actuating the switch ⑥. The enclosing tube provides a static pressure boundary between the switch mechanism and the process. On a falling level, an inconel spring retracts the magnet, deactivating the switch.



#### SPECIFICATIONS

#### SWITCH MECHANISMS AND ENCLOSURES

#### SERIES B, C, D & R DRY CONTACT SWITCHES

- · Dry contact for most applications
- Designs for AC and DC current applications
- Process temperatures to +1000° F (+538° C)



#### SERIES F, HS, H1, 8 & 9 HERMETICALLY SEALED SWITCHES

- Ideal for use in salt and other corrosive atmospheres
- Positively pressurized capsules for entire mechanism and contacts
- Process temperatures to +1000° F (+538° C)



#### SERIES J & K PNEUMATIC SWITCHES

- Suited for applications where electrical power is not available
- · Bleed and non-bleed designs
- Process temperatures to +400° F (+204° C)



#### **SWITCH ENCLOSURES**

- TYPE 4X/7/9 aluminum enclosures
- Designed to meet Class I, Div. 1, Groups C & D and Class I, Div. 1 Group B
- Optional housing heaters and drains available for some enclosures
- Pneumatic switch mechanisms available with a NEMA 1 enclosure



#### **BASIC ELECTRICAL RATINGS**

Veltore	Switch Series and Non-Inductive Ampere Rating														
Voltage	В	С	D	F	HS	H1	R	8	9						
120 VAC	15.00	15.00	10.00	2.50	5.00	1.00	1.00	1.00	_						
240 VAC	15.00	15.00	_	_	5.00	1.00	1.00	_	_						
24 VDC	6.00	10.00	10.00	4.00	5.00	1.00	1.00	3.00	0.50						
120 VDC	0.50	1.00	10.00	0.30	0.50	0.40	0.40	_	_						
240 VDC	0.25	0.50	3.00	_	0.25	_	_	_	_						

## AGENCY APPROVALS

AGENCY	APPROVED MODEL	AREA CLASSIFICATION
FM FM>	All with an electric switch mechanism and a housing listed as TYPE 4X	Non-Hazardous TYPE 4X
APPROVED	All with an electric switch mechanism and a housing listed as TYPE 4X/7/9	Class I, Div 1, Groups C & D Class II, Div 1, Groups E, F & G
	All with an electric switch mechanism and a housing listed as TYPE 4X/7/9 Class I, Div 1, Group B	Class I, Div 1, Groups B, C & D Class II, Div 1, Groups E, F & G
CSA	All with an electric switch mechanism and a housing listed as CSA TYPE 4X	Non-Hazardous CSA TYPE 4X
	All with a Series HS, H1, F, 8 or 9 electric switch mechanism and a housing listed as CSA TYPE 4X	Class I, Div 2, Groups B, C & D
	All with an electric switch mechanism and a housing listed as TYPE 4X/7/9	Class I, Div 1, Groups C & D Class II, Div 1, Groups E, F & G
	All with an electric switch mechanism and a housing listed as TYPE 4X/7/9 Class I, Div 1, Group B	Class I, Div 1, Groups B, C & D Class II, Div 1, Groups E, F & G
ATEX / IEC Ex ②	All with an electric switch mechanism and an ATEX housing $\ensuremath{\mathbb{O}}$	ATEX II 2 G EEx d IIC T6 94/9/EC IEC Ex Ex d IIC T6 IP 66
CE ( <b>(</b>	Low Voltage Directive 2006/95/EC Per Harmonized Standard: EN 61010-1/1993 & Amendment No. 1	Installation Category II Pollution Degree 2

 $<sup>\</sup>ensuremath{\textcircled{1}}$  Dual stage units with 'HS' or 'H1' switches are not ATEX approved.

The cable entry and closing devices shall be Ex d certified suitable for the conditions of use and correctly installed. For ambient temperatures above +55° C or for process temperatures above +150° C, suitable heat resistant cables shall be used.

Heat extensions (between process connection and housing) shall never be insulated.

#### Special conditions for safe use:

When the equipment is installed in process temperatures higher than +85° C the temperature classification must be reduced according to the following table as per IEC60079-0.

Maximum Process Temperature	Temperature Classification
< 85° C	Т6
< 100° C	T5
< 135° C	T4
< 200° C	Т3
< 300° C	T2
< 450° C	T1

These units are in conformity with IECEx KEM 05.0020X Classification Ex d IIC T6  $\,$ 

② IEC Installation Instructions:

T<sub>ambient</sub> -40° C to +70° C

# DIMENSIONAL SPECIFICATIONS

INCHES (mm)

#### **CHAMBERS WITH 1-INCH CONNECTIONS**

#### **INCHES**

#### **MILLIMETERS**

	Min. Sp. Gr.	I INT	T Thre	eaded Weld	1	1" Flanged pper Side/Bottom		1" Flanged m Side/Side			Actuating 1" NPT Threa & Socket W						1" Flanged Side/Side			Actuating Levels			
		Α	В	С	Α	В	С	Α	В	С	HL	LL	Α	В	С	Α	В	С	Α	В	С	HL	LL
C29	.76	9.94	3.02	13.50	12.81	5.87	16.44	13.46	5.87	17.06	2.95	3.85	252	76	342	325	149	417	341	149	433	74	97
D30	.65	9.19	3.27	12.75	12.06	6.12	15.63	12.71	6.12	16.25	2.50	3.33	233	83	323	306	155	397	322	155	412	63	84
J30	.48	10.10	1 22	1462	13.06	7.18	17.50	10 71	7 10	10 10	2.61	3.34	258	109	371	331	182	444	348	182	460	66	84
L30	.40	10.19	4.33	14.03	13.00	7.10	17.50	13.71	7.10	10.19	3.24	3.98	200	109	3/1	331	102	444	340	102	402	82	101
B60	.68	9.81	2 90	14.25	12.68	6.68	17.12	10 00	6 60	17 75	2.77	3.44	248	96	361	322	169	434	338	160	450	70	87
C60	.55	9.01	3.00	14.23	12.00	0.00	17.12	13.33	0.00	17.73	2.87	3.60	240	90	301	322	109	434	336	109	430	72	91

Levels ±0.25" (6 mm)

#### CHAMBERS WITH 1½-INCH CONNECTIONS

**INCHES** 

#### MILLIMETERS

	Min. Sp. Gr.		PT Throcket V	eaded Veld		" Flang Side/E	ed Bottom	1½" Flanged Side/Side			Actuating Levels		1½" NPT Threaded & Socket Weld						1½" Flanged Side/Side			Actua Lev	ating rels
		Α	В	С	Α	В	С	Α	В	С	HL	LL	Α	В	С	Α	В	С	Α	В	С	HL	LL
C29	.76	9.75	3.44	14.38	13.81	6.87	18.38	14.46	6.87	19.06	2.02	2.92	247	87	365	350	174	466	367	174	484	51	74
D30	.65	9.00	3.69	13.12	13.06	7.12	17.19	13.71	7.12	17.88	1.87	2.70	228	93	333	331	180	436	348	180	454	47	68
J30	.48	10.00	1 75	15.06	14.06	0 10	19.12	1/1 71	0 10	10.75	1.97	2.70	254	120	382	357	207	485	27/	207	501	50	68
L30	.40	10.00	4.75	15.00	14.00	0.10	19.12	14.71	0.10	19.75	2.60	3.34	254	120	302	337	207	465	374	207	301	66	84
B60	.68	9.62	4 22	14.69	13.68	7.68	18.75	1/1 22	7 69	19.38	1.46	2.13	244	107	373	347	195	476	363	195	402	37	54
C60	.55	9.02	4.22	14.09	13.00	1.00	10.75	14.33	7.00	19.30	1.93	2.66	244	107	3/3	347	193	4/0	303	195	432	49	67

Levels ±0.25" (6 mm)

#### **CHAMBERS WITH 2-INCH CONNECTIONS**


INCHES

#### **MILLIMETERS**


	Min. Sp. Gr.	l	T Thre	eaded Veld	eld Upper Side/Bottom Side/Side L		•			Jpper Side/Bottom Sid				ating /els	& Socket Weld			2" Flanged Upper Side/Bottom			2" Flanged Side/Side			Actuating Levels	
		Α	В	С	Α	В	С	Α	В	С	HL	LL	Α	В	С	Α	В	С	Α	В	С	HL	LL		
C29	.76	10.00	3.56	14.44	13.81	6.87	18.25	14.46	6.87	18.94	2.02	2.97	254	90	366	350	174	463	367	174	481	52	75		
D30	.65	8.75	3.81	13.25	13.06	7.12	17.56	13.71	7.12	18.25	1.50	2.33	222	96	336	331	180	446	348	180	463	38	59		
J30	.48	0.74	1 07	15 10	14.06	8.18	19.50	1171	0 10	20.12	1.60	2.33	247	123	385	357	207	495	274	207	511	40	59		
L30	.40	9.74	4.07	15.19	14.00	0.10	19.50	14.71	0.10	20.12	2.23	2.97	241	123	303	337	207	495	374	201	311	56	75		
B60	.68	9.38	121	14.81	13.68	7.68	19.12	14 22	7 60	19.75	1.52	2.19	238	110	376	347	195	485	363	195	501	38	55		
C60	.55	9.30	4.34	14.01	13.00	7.00	19.12	14.33	1.00	19.73	1.99	2.72	230	110	376	347	195	400	303	195	301	50	69		


Levels ±0.25" (6 mm)

#### INCHES (mm)



**Threaded and Socket Weld** 





Side/Bottom Flanged

#### Conduit Connections D

Electrical Switches
TYPE 4X/7/9: 1" NPT
Group B: 1" NPT
Pneumatic Switches
NEMA 1: ¼" NPT

#### NOTES:

- Switch actuating levels (HL & LL) are given for minimum specific gravity conditions. Levels will be lower in the float chamber for higher specific gravities.
- Standard process connections are a combination of 1" NPT and 1" socket weld coupling.
- 3. Allow overhead clearance of 10 inches (254 mm) for TYPE 4X/7/9 housing.

Models available for quick shipment, usually within one week after factory receipt of a complete purchase order, through the Expedite Ship Plan (ESP)

#### MODEL NUMBER CODE

(1)	Minimum Spec	•	Pressure Rating											
Model	Material of Cons	truction Code		psig @ ° F bar @ ° C										
No.	1	2	100	750	900	1000	38	399	482	538				
C29	0.76	0.81	500	403	388	383	34	28	27	26				
D30 ③	0.65	0.69	250	201	194	191	17	14	13	13				
J30	0.48	0.51	400 ④	322 ④	310	167	28 ④	22 ④	21	12				
L30	0.40	0.42	300 ④	242 ④	233	167	21 ④	17 ④	16	12				
B60	0.68	0.71	900	725	496	182	62	50	34	13				
C60	0.55	0.59	500	403	388	182	34	28	27	13				

#### MATERIALS OF CONSTRUCTION

1	Carbon steel chamber, 316 stainless steel float, 400 stainless steel sleeve
2	Carbon steel chamber, 316 stainless steel float, 316 stainless steel sleeve

#### TANK CONNECTION TYPE AND SIZE

	1											
Connection				Coi	nection S	Size						
Туре		1"			11/2"			2"				
Threaded Side/Bottom		B20			C20			D20				
Socket Weld Side/Bottom		B30			C30			D30				
			Ca	ge Mount	ing Flange	Rating (I	bs.)	bs.)				
	150	300	600	150	300	600	150	300	600			
Flanged Upper Side/Bottom	N30	N40	N50	P30	P40	P50	Q30	Q40	Q50			
Flanged Side/Side	S30	S40	S50	T30	T40	T50	V30	V40	V50			


Connection flanges are ASME B16.5 raised face.

#### PNEUMATIC SWITCH MECHANISM AND ENCLOSURE

Switch	Su	imum pply ssure	Pro	mum cess erature	Ble Orif Diam	ice	Model Material of 0 Code 1	s with Construction Code 2
Description	psig	bar	°F	° C	inches	mm	NEMA 1	NEMA 1
Series J	100	7	+400	+204	.063	1.6	JDG	JDE
Bleed Type	60	4	+400	+204	.094	2.3	JEG	JEE
Series K	100	7	+400	+204	_	_	KOE	KOE
Non-Bleed	40	3	+400	+204	_	_	KOG	_

Electric switch mechanism and enclosure codes on next page

- Models are limited to maximum temperature rating of selected switch mechanisms.
- $\ensuremath{@}$  For single stage models only. Consult factory for multiple stages.
- $\ensuremath{\,^{\circlearrowleft}}$  Model D30 recommended for Dowtherm applications.
- ④ Float cage rated 600 psig @ +100° F (41 bar @ +38° C) and 340 psig @ +750° F (23 bar @ +399° C).
- ⑤ Process temperature based on +100° F (+38° C) ambient.
- © Consult factory for NEMA 4X//9 cast iron housing codes.
- $\ensuremath{\mathfrak{D}}$  On condensing applications, temperature down-rated to +400° F (+209° C) process at +100° F (+38° C) ambient.



Process ® mperature Range °F (°C)  40 to +250 (10 to +121)  40 to +450 (10 to +232)  40 to +232)  40 to +250 (10 to +121)  50 to +750 (16 to +399)  50 to +550 (16 to +288)	SPDT DPDT SPDT DPDT SPDT DPDT SPDT DPDT	Set Points  1	Class I, Div 1 Groups C&D  BKA BLA BMA BNA CKA CLA CMA CNA COA DKB DLB	Class I, Div 1 Group B  BKJ BLJ BMJ BNJ BOJ CKJ CLJ CMJ CNJ	ATEX EX II 2 G EEX d IIC T6  BCC BDC BEC BFC BGC CCC CDC CEC CFC	Class I, Div 1 Groups C&D  BKB BLB BNB BNB BOB CKB CLB CMB	Class I, Div 1 Group B  BKK BLK BMK BNK BOK CKK CLK CMK	ATEX Ex II 2 G EE d IIC T6 BC9 BD9 BE9 BF9 BG9 CC9 CD9 CE9
°F (°C)  40 to +250 40 to +121)  40 to +450 40 to +232)  40 to +232)  40 to +250 40 to +121)  50 to +750 46 to +399)	SPDT DPDT SPDT DPDT SPDT DPDT	1 2 3 1 2 1 2 3 1 2 1 2 3 1 2 3 1 2 3 1 2 1 2	BKA BLA BMA BNA BOA CKA CLA CMA CNA COA DKB	BKJ BLJ BMJ BNJ BOJ CKJ CLJ CMJ CNJ	Ex II 2 G EEX d IIC T6 BCC BDC BEC BFC BGC CCC CDC	BKB BLB BMB BNB BOB CKB CLB CMB	BKK BLK BMK BNK BOK CKK CLK CMK	Ex II 2 G EE d IIC T6 BC9 BD9 BE9 BF9 BG9 CC9 CD9
40 to +450 40 to +232) 40 to +232) 40 to +250 40 to +121) 50 to +750 46 to +399)	DPDT SPDT DPDT SPDT DPDT	2 3 1 2 1 2 3 1 2 1 2 1 2 3 1 2	BLA BMA BNA BOA CKA CLA CMA CNA COA DKB	BLJ BMJ BNJ BOJ CKJ CLJ CMJ CNJ	BDC BEC BFC CCC CDC CEC	BLB BMB BNB BOB CKB CLB	BLK BMK BNK BOK CKK CLK	BD9 BE9 BF9 BG9 CC9 CD9
40 to +450 40 to +232) 40 to +232) 40 to +250 40 to +121) 50 to +750 46 to +399)	DPDT SPDT DPDT SPDT DPDT	3 1 2 1 2 3 1 2 1 2 3 1 2 1 2 3 1	BMA BNA BOA CKA CLA CMA CNA COA DKB	BMJ BNJ BOJ CKJ CLJ CMJ CNJ COJ	BEC BFC BGC CCC CDC CEC	BMB BNB BOB CKB CLB	BMK BNK BOK CKK CLK CMK	BE9 BF9 BG9 CC9 CD9
40 to +450 40 to +232) 40 to +232) 40 to +250 40 to +121) 50 to +750 46 to +399)	SPDT DPDT SPDT DPDT	1 2 1 2 3 1 2 2 3 1 1	BNA BOA CKA CLA CMA CNA COA DKB	BNJ BOJ CKJ CLJ CMJ CNJ COJ	BFC BGC CCC CDC CEC	BNB BOB CKB CLB CMB	BNK BOK CKK CLK CMK	BF9 BG9 CC9 CD9
40 to +232) 40 to +250 40 to +121) 50 to +750 46 to +399) 50 to +550	SPDT DPDT SPDT DPDT	2 1 2 3 1 2 1 2 3 1	BOA CKA CLA CMA CNA COA DKB	BOJ CKJ CLJ CMJ CNJ COJ	BGC CCC CDC CEC	BOB CKB CLB CMB	BOK CKK CLK CMK	BG9 CC9 CD9
40 to +232) 40 to +250 40 to +121) 50 to +750 46 to +399) 50 to +550	DPDT SPDT DPDT	1 2 3 1 2 1 2 3 1	CKA CLA CMA CNA COA DKB	CKJ CLJ CMJ CNJ COJ	CCC CDC CEC	CKB CLB CMB	CKK CLK CMK	CC9 CD9
40 to +232) 40 to +250 40 to +121) 50 to +750 46 to +399) 50 to +550	DPDT SPDT DPDT	2 3 1 2 1 2 3 1	CLA CMA CNA COA DKB	CLJ CMJ CNJ COJ	CDC CEC	CLB CMB	CLK CMK	CD9
40 to +232) 40 to +250 40 to +121) 50 to +750 46 to +399) 50 to +550	DPDT SPDT DPDT	3 1 2 1 2 3 1	CMA CNA COA DKB	CMJ CNJ COJ	CEC	CMB	CMK	
40 to +250 40 to +121) 50 to +750 46 to +399)	SPDT	1 2 1 2 3 1	CNA COA DKB	CNJ COJ				
40 to +121) 50 to +750 46 to +399) 50 to +550	SPDT	2 1 2 3 1	COA DKB	COJ		CIND	CNK	CF9
40 to +121) 50 to +750 46 to +399) 50 to +550	DPDT	2 3 1			CGC	COB	COK	CG9
40 to +121) 50 to +750 46 to +399) 50 to +550	DPDT	3	DLB	DKK	DC9	DKB	DKK	DC9
40 to +121) 50 to +750 46 to +399) 50 to +550		1		DLK	DD9	DLB	DLK	DD9
50 to +750 46 to +399) 50 to +550				N/A		DMB	DMK	DE9
16 to +399) 50 to +550			DNB	DNK	DF9	DNB	DNK	DF9
16 to +399) 50 to +550	SPDT	2	DOB	DOK	DG9	DOB	DOK	DG9
16 to +399) 50 to +550	J. D.	1	FKA	FKJ	FCC	FKB	FKK	FC9
50 to +550		2	FLA	FLJ	FDC	FLB	FLK	FD9
	DPDT	1	FNA	FNJ	FFC	FNB	FNK	FF9
		2	FOA	FOJ	FGC	FOB	FOK	FG9
	SPDT	1	HMJ	HMK		HMJ	HMK	
י יססי+ טן סוּ		2	HMN	HMP	N/A	HMN	HMP	N/A
	DPDT	2	HMS HMY	HMT HMZ		HMS HMY	HMT HMZ	-
		2	HIVIY	HIVIZ		HIVIY	HIVIZ	
50 to +550 16 to +288)	SPDT	1	НМ3	HM4	HA9	НМ3	HM4	HA9
10 10 +200)	DPDT	1	HM7	HM8	HB9	HM7	HM8	HB9
50 to +750 16 to +399)	SPDT	1	HKJ	HKK	N/A	HKJ	HKK	N/A
10 (0 +399)		2	HKN	HKP		HKN	HKP	200
	SPDT							RC9
								RD9
10 (0 +399)	DPDT							RF9 RG9
								8C9
	SDUT							8D9
50 to +750	31 11							8E9
16 to +399)								8F9
	DPDT							8G9
		1	9KA	9KJ	9CC	9KB	9KK	9C9
	SPDT	2	9LA	9LJ	9DC	9LB	9LK	9D9
		3	9MA	9MJ	9EC	9MB	9MK	9E9
+U IU +399)	DDDT	1	9NA	9NJ	9FC	9NB	9NK	9F9
	וטאט	2	90A	9OJ	9GC	9OB	90K	9G9
			CS/Aluminum			CS/Aluminum		
			NEMA 4X	Groups C&D	Class I, Div 1 Group B	NEMA 4X	Groups C&D	Group B
	SPDT	1	R1M	RKM	RKW	R1M	RKM	RKW
0 to +1000	OF D I	2	R3M	RLM	RLW	R3M	RLM	RLW
16 to +538)	DPDT	1	RDM	RNM	RNW	RDM	RNM	RNW
	2, 2,							ROW
		1	9AD		9KV	9AM		9KW
0 to +1000	SPDT							9LW
16 to +538)								9MW
/	DPDT							9NW
		2	1 9ED	900	907	9EM	1 90M	9OW
550	to +1000 to +1000 to +1000	0 to +750 0 to +399) DPDT 0 to +750 6 to +399) DPDT SPDT 0 to +750 6 to +399) DPDT to +1000 6 to +538) DPDT SPDT SPDT SPDT SPDT SPDT SPDT SPDT SPDT	SPDT   1   2   2   1   2   2   2   2   2   2	SPDT   1	SPDT   1	SPDT   1	SPDT   1	SPDT   1



The quality assurance system in place at Magnetrol guarantees the highest level of quality throughout the company. Magnetrol is committed to providing full customer satisfaction both in quality products and quality service.

The Magnetrol quality assurance system is registered to ISO 9001 affirming its commitment to known international quality standards providing the strongest assurance of product/service quality available.

#### E S P

# Expedite Ship Plan

Several Flanged External Cage Level Switches are available for quick shipment, usually within one week after factory receipt of a complete purchase order, through the Expedite Ship Plan (ESP).

To take advantage of ESP, match the color coded model number codes in the selection charts (standard dimensions apply).

ESP service may not apply to orders of ten units or more. Contact your local representative for lead times on larger volume orders, as well as other products and options.

#### WARRANTY



All Magnetrol mechanical level and flow controls are warranted free of defects in materials or workmanship for five full years from the date of original factory shipment.

If returned within the warranty period; and, upon factory inspection of the control, the cause of the claim is determined to be covered under the warranty; then, Magnetrol will repair or replace the control at no cost to the purchaser (or owner) other than transportation.

Magnetrol shall not be liable for misapplication, labor claims, direct or consequential damage or expense arising from the installation or use of equipment. There are no other warranties expressed or implied, except special written warranties covering some Magnetrol products.

**BULLETIN: 46-116.22** 

**EFFECTIVE: August 2010** 

SUPERSEDES: July 2009



5300 Belmont Road • Downers Grove, Illinois 60515-4499 • 630-969-4000 • Fax 630-969-9489 • www.magnetrol.com 145 Jardin Drive, Units 1 & 2 • Concord, Ontario Canada L4K 1X7 • 905-738-9600 • Fax 905-738-1306 Heikensstraat 6 • B 9240 Zele, Belgium • 052 45.11.1 • Fax 052 45.09.93 Regent Business Ctr., Jubilee Rd. • Burgess Hill, Sussex RH15 9TL U.K. • 01444-871313 • Fax 01444-871317