



Emergency Escape Signs

Fire Exit Signs

1. Fire Exit Signs must contain a symbol.
2. Worded exit signs are no longer acceptable
3. All Brady Emergency Escape Signs are in compliance with the requirements of Directive BS5499 and the Health and Safety Regulations 1996

Pictogram	Size in mm (H x W)	Selfadhesive Vinyl B-930	Rigid PVC B-7526	Pictogram	Size in mm (H x W)	Selfadhesive Vinyl B-930	Rigid PVC B-7526
Fire exit				Fire exit			
STE 108	150 x 450 250 x 750	259080 259082	259081 259083	STE 109	150 x 450 250 x 750	259084 259086	259085 259087
Fire exit				Fire exit			
STE 110	150 x 450 250 x 750	259088 259090	259089 259091	STE 111	150 x 450 250 x 750	259092 259094	259093 259095
Fire exit				Fire exit - For emergency use only This door is alarmed			
STE 112	150 x 450 250 x 750	259096 259098	259097 259099	STE 113	300 x 450	259100	259101
Emergency exit - Keep clear				Fire exit - Keep Clear			
STE 114	300 x 450	259102	259103	STE 115	300 x 450	259104	259105

Health Care Signs

These signs meet the requirements of the HTM 65 (Health & Technical Memorandum) for use in hospitals and health centres. The additional flame symbol enhances and clarifies the meaning of the safety sign.

Fire exit (NHS: HTM 65)				Fire exit (NHS: HTM 65)			
STE 116	150 x 450 250 x 750	259106 259108	259107 259109	STE 117	150 x 450 250 x 750	259110 259112	259111 259113
Fire exit (NHS: HTM 65)				Fire exit (NHS: HTM 65)			
STE 118	150 x 450 250 x 750	259114 259116	259115 259117	STE 120	150 x 450 250 x 750	259122 259124	259123 259125
Fire exit (NHS: HTM 65)				Fire exit (NHS: HTM 65)			
STE 119	150 x 450 250 x 750	259118 259120	259119 259121	STE 121	150 x 450 250 x 750	259126 259128	259127 259129