

EWTO

ELECTRICIANS' GLOVES AND GAUNTLETS

**COMPETITIVE
PRICES**

**PROMPT
DELIVERY**

TO BRITISH STANDARD SPECIFICATION 697/1986

- NATURAL COLOUR
- SEAMLESS CONSTRUCTION
- CURVED FINGERS TO ENSURE MAXIMUM COMFORT, FLEXIBILITY AND SENSITIVITY IN HAND OPERATION
- MANUFACTURED, INSPECTED AND TESTED FULLY IN ACCORDANCE WITH BSS 697/1986
- APPROPRIATE WORKING VOLTAGE PRINTED ON GLOVE
- ALL GLOVES AND GAUNTLETS SUPPLIED IN POLYTHENE BAGS LIBERALLY DUSTED WITH PURIFIED TALC B P Quality.
- MAINTENANCE TEST SERVICE AVAILABLE
- AVAILABLE IN THREE STANDARD LENGTHS
- ~~ALL GLOVES AND GAUNTLETS SUPPLIED IN POLYTHENE BAGS LIBERALLY DUSTED WITH PURIFIED TALC B P Quality.~~



	WORKING VOLTAGE	TEST VOLTAGE	AVAILABLE HAND SIZES	PRINTING COLOUR	AVAILABLE LENGTHS ALL VOLTAGES
GLOVES AND GAUNTLETS	650 1,000 3,300 4,000	5,000 10,000 15,000 20,000	8,9,10 or 11 8,9,10 or 11 9,10 or 11 9,10 or 11	WHITE RED GREEN BLUE	12" - 305mm 14" - 356mm 17" - 432mm

MAINTENANCE TEST SERVICE

- BY THIS SERVICE OF MAINTENANCE TESTING AT 6-MONTHLY INTERVALS, SAFETY AS FAR AS IS PRACTICALLY POSSIBLE IS MAINTAINED THROUGHOUT THE WORKING LIFE OF THE GLOVES AND GAUNTLETS AND THE REGULATIONS AND REQUIREMENTS OF THE HOME OFFICE AND FACTORY ACTS ARE SATISFIED
- A CERTIFICATE OF SATISFACTORY RE-TEST IS ISSUED
- GLOVES AND GAUNTLETS WHICH FAIL THE RE-TEST ARE DESTROYED BY US, THUS, IN THE INTERESTS OF SAFETY, ENSURING THAT FAILED GLOVES ARE NOT INADVERTENTLY RE-ISSUED TO THE USER.

ELECTRICAL SAFEGUARDS

Division of
Insulated
Tools Ltd.

SUGGESTIONS FOR THE CARE AND MAINTENANCE OF 'EWTO' ELECTRICIANS' GLOVES AND GAUNTLETS

- 1 We supply each pair of gloves in a substantial gauge polythene bag, dusted with Purified Talc BP quality to preclude moisture, and recommend that every effort be made to keep the gloves in this condition.
- 2 To avoid material stresses, the gloves should never be folded.
- 3 In order to guard against the harmful effects of ultra violet light, and to afford protection against accidental damage of any sort, it is strongly recommended that the gloves be stored in an outer container of heavy gauge durable plastic. Storage temperatures should be between 10° C and 21° C.
- 4 Immediately prior to use, all gloves should be subjected to a thorough visual inspection, and if there is any doubt as to their condition, they should be returned for re-testing.
- 5 Any contamination brought about by contact with harmful materials or chemicals should be treated by the use of an approved solvent, then washed with soap and warm water, and carefully dried without the application of excessive heat. The use of petroleum based solvents is NOT RECOMMENDED.
- 6 (a) Gloves subjected to constant use should be re-tested every six months.
(b) Gloves used infrequently or stored for emergency use should be re-tested every 12 months.
(c) It is recommended that all gloves whether issued for use, or held in Stores, are at all times covered by a valid Test Certificate.

GENERAL:

- (a) Electrical Safeguards supply a full range of Gloves and Gauntlets manufactured and tested fully in accordance with BSS 697/1986. Signed, dated, and numbered Test Certificates are also provided.
- (b) Electrical Safeguards operate a Maintenance Re-test Service on any make of Electricians' Gloves and Gauntlets. Test Certificates are provided to cover all satisfactorily re-tested Gloves and Gauntlets.
- (c) Electrical Safeguards supply suitable plastic containers for the storage of Electricians' Gloves and Gauntlets.

Charlwoods Road
East Grinstead
West Sussex. RH19 2HR
ENGLAND
Tel. No. 0342 325100
Fax. 0342 327115
